



INTERPRETATION:IIAR SRC 2001-1SUBJECT:ANSI/IIAR 2-1999, SECTION 5.15DATE ISSUED:AUGUST 23, 2001

QUESTION:

In the city of Chicago, the installation of a "Fireman's Dump" is required. The dump is connected to the low side of the refrigeration system and, in case of an emergency, it allows the ammonia charge to be mixed with water by the fire department and dumped into the sewer.

Is the piping after the ammonia/water mixer considered part of the refrigeration system?

REPLY:

NO

COMMITTEE ACTION:

The Standards Review Committee has added the need to more broadly define "Mechanical Refrigerating Systems " to its list of issues for the next major IIAR 2 revision.