



1001 N. Fairfax St., Suite 503 • Alexandria, VA 22314  
703-312-4200 • F: 703-312-0065

[www.iiar.org](http://www.iiar.org)

INTERPRETATION: IIAR SC 2018-1

SUBJECT: Flexible Connectors for Relief Piping

QUESTION: Are flexible hose connections sufficient to serve as connective piping between relief valve outlets and the associated relief discharge header piping?

ANSWER:

Yes, flexible hose connections could comply with ANSI/IIAR 2-2104 in this type of application.

COMMITTEE ACTION: None